

Note: Any verbiage written in red needs to be specified. All other options should be deleted

KYLER SANI-PANE INSULATED BLIND SPECIFICATION

PART 1 – GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:

- 1. Kyler Sani-Pane insulated glass blind

- B. Related Sections:

- 1. Division 8 Section “Steel Doors and Frames” for hollow metal frames.
 - 2. Division 8 Section “Glazing” for standard glass products.

1.3 DEFINITIONS

- A. Glazing Manufacturers: Firms that produce primary glass, as defined in referenced glazing publications.
- B. Interspace: Air space between lites of insulating glass blind.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: Include elevations, edge details, hardware, and attachments to other work.
- C. Samples: For the following products, in the form of 15 x 18 -inch square Samples for glass.
- D. Warranties: Sample of special warranties.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: A qualified installer who employs glass installers for this Product who are certified under the National Glass Association’s Certified Glass Installer Program.
- B. Source Limitations for Insulated Glass Blinds: Obtain insulated glass blinds from single source from single manufacturer.
- C. Glazing Publications: Comply with the following published recommendations:

DIVISION 8 – DOORS AND WINDOWS
SECTION 08813 – INSULATING GLASS BLIND SYSTEMS

1. GANA's "Glazing Manual" unless more stringent requirements are indicated. Refer to this publication for definitions of glass and glazing terms not otherwise defined in this Section or in referenced standards.
- D. Safety Glazing Products: For Tempered insulating glass blind systems, provide products complying with testing requirements in 16 CFR 1201 for Category II materials.
- E. Safety Glazing Labeling: Where safety glazing labeling is indicated, permanently mark glazing with certification label of the SGCC or another certification agency acceptable to authorities having jurisdiction or the manufacturer. Label shall indicate manufacturer's name, type of glass, thickness, and safety glazing standard with which glass complies.
- 1.6 DELIVERY, STORAGE, AND HANDLING
 - A. Insulated glass blinds to be stored indoors at all times. Prevent damage caused by temperature changes (condensation), and direct exposure to sun light or rain.
- 1.7 PROJECT CONDITIONS
 - A. Environmental Limitations: Insulated glass blinds are intended for interior usage only. Installation in exterior application voids manufacturer's product warranty.
- 1.8 COORDINATION
 - A. Coordinate dimensions, including thickness, of insulated glass blind with dimensions of construction that receives insulated glass blind. Framing details must be examined for compliance prior to ordering product.
- 1.9 WARRANTY
 - A. Manufacturer's Warranty on insulated glass blinds: Manufacturer agrees to replace insulated glass blind units that fail to perform within the specified warranty period. operational deficiencies as a result of improper installation are not covered under warranty.
 1. Warranty Period: 5 years from date of Substantial Completion.

PART 2 – PRODUCTS

KYLER SANI-PANE INSULATED GLASS BLIND

- A. Kyler Sani-Pane Insulated Glass Blind: Mechanically gear-driven micro-blind installed between two lites of glass, with internally-mounted control assembly coupled to an external Operator(s) which in turn control the tilt function of the internal blind slats.
 1. Air Space: ¾ inch. Clear anodized
 2. Tilt Operator Type; specify:
 - a. Angle knob
 - b. Thumb wheel
 3. Specify:
 - a. Single control – allows tilt operation from one side of the unit
 - b. Dual control – allows tilt operation from both sides of the unit
 4. Tilt Operator Location as specified by Architect; specify desired location on vertical side(s) of unit

DIVISION 8 – DOORS AND WINDOWS
SECTION 08813 – INSULATING GLASS BLIND SYSTEMS

B. Horizontal Louver Blinds, Aluminum Slats:

1. Slats: 6010-T8 aluminum alloy, 0.625-inch wide by 0.008-inch thick, with crowned profile.
2. Spacing: Manufacturer's standard.
3. Finish: One color, baked polyester paint ultra-violet-resistant finish.
4. Head and Bottom Rails: 6063-T5 aluminum alloy, painted in coordinated color with slats.
5. Ladder Tapes and Plisse Cords: Thermally-fixed polyester, UV resistant, and evenly spaced to prevent long-term slat sag.
6. Tilt Operating Mechanism: Injected molded glass filled nylon mounted to a solid brass core. Internal mechanism is comprised of solid brass and aluminum. Color to be black.
7. Colors, Textures, Patterns, and Gloss: **Select from Manufacturer's standard color options:**
 - a. #102 White
 - b. #149 Almond
 - c. #69 Tan
 - d. #3000 Metallic Gold
 - e. #0157 Silver

C. Insulated Glass blinds: Factory assembled units consisting of two lites of tempered glass separated by a ¾ inch clear anodized air spacer, with an internal blind.

1. Heat-Treated Float Glass: ASTM C 1048; Type 1; Quality-Q3; Class 1 (clear) unless otherwise indicated; of kind and condition indicated.
 - a. Fabrication Process: By horizontal (roller-hearth) process with roll-wave distortion parallel to bottom edge of glass as installed unless otherwise indicated.
 - b. All glass to be fully tempered float glass.
2. Glass Thickness: 3/16 inch, minimum. Provide glazing in thicknesses/type as needed to comply with requirements indicated.
3. Overall Thickness insulated glass blind: 1 inch glazing pocket
4. Seal with manufacturer's standard sealant.
5. Air spacer: Manufacturer's standard clear anodized spacer material and construction.
6. Desiccant: Molecular sieve or silica gel, or blend of both.

D. Perimeter Sub-Frame

1. Entire perimeter Sub-frame consists of .062 thick extruded aluminum.
 - a. All sub-frame corners are cut (45 degree) and mechanically fastened with concealed fasteners.
2. Sub-frame color: Select from manufacturer's standard colors **specify white, almond, tan, clear anodized, or dark Bronze anodized.**
Or specify:
 - a. **Factory Custom color paint**
 - b. **Factory Custom Anodized – specify color**
 - c. **Factory profile wrapped wood veneer – specify wood species type and factory finish type/ or field finish.**

E. Basis-of-Design Manufacturer: Subject to compliance with requirements, provide:

Kyler Industries
192 East 48th Street
Holland, MI 49423
(616) 392-1042 (voice)
(616) 392-3778 (fax)
www.Kyler-Industries.com

F. Miscellaneous Glazing Materials: Refer to Division 8 Section "Glazing".

2.1 FABRICATION

DIVISION 8 – DOORS AND WINDOWS
SECTION 08813 – INSULATING GLASS BLIND SYSTEMS

A. Tolerances:

1. Space of approximately 1/8 inch on each side between slats and spacer, for free movement of system and allowing thermal transmission of aluminum slats.
2. Blind Width Tolerance: Plus zero; minus 1/16 inch.
3. Blind Height Tolerance: Plus 3/8 inch; minus zero. Bottom rail engages pins in vertical air spacer. with some slack and is slightly above bottom air spacer.

PART 3 – EXECUTION

3.1 EXAMINATION

- A. Examine framing of insulating glass blind, with Installer present, for compliance with requirements for installation tolerances, minimum required face or edge clearances, and other conditions affecting performance of the Work.
- B. Proceed with installation only after satisfactory conditions have been verified.

3.2 PREPARATION

- A. Clean glazing channels and other framing members receiving insulating glass blinds immediately before glazing. Remove coatings not firmly bonded to substrates.

3.3 INSTALLATION

- A. Install insulating glass blind according to manufacturer's written instructions.
- B. Refer to Division 8 Section "Glazing" for installation of insulating glass blind units

3.4 ADJUSTING, CLEANING, AND PROTECTIONS

- A. Clean glass and perimeter frame of insulated glass blinds.
 1. Remove nonpermanent labels, and clean surfaces.
- B. Protect insulated glass blind units from damage immediately after installation by attaching crossed streamers to framing held away from glazing unit. Do not apply markers to security glazing surfaces.
- C. Protect insulated glass blind units from contact with contaminating substances resulting from construction operations, including weld splatter. If, despite such protection, contaminating substances do come into contact with insulating glass blind system units, remove immediately.
- D. Remove and replace all insulated glass blind units that are broken, chipped, cracked, or abraded or that are damaged from natural causes, accidents, or vandalism during construction period.
- E. Wash insulated glass blind units on exposed surfaces in each area of Project not more than four days before date scheduled for inspections that establish date of Substantial Completion. Wash insulating glass blind units as recommended in writing by insulating glass blind manufacturer.

END OF SECTION 08813